

CITY OF SEAGRAVES
MCL, AVERAGE / ARSENIC QUARTER FOUR 2021

The Texas Commission on Environmental Quality (TCEQ) has notified the **CITY OF SEAGRAVES TX0830001** that the drinking water being supplied to customers had exceeded the Maximum Contaminant Level (MCL) for arsenic. The U.S. Environmental Protection Agency (U.S. EPA) has established the MCL for arsenic at 0.010 milligrams per liter (mg/L) based on running annual average (RAA) and has determined that it is a health concern at levels above the MCL. Analysis of drinking water in your community for arsenic indicates a compliance value in **QUARTER FOUR 2021** of 0.035 mg/L for EP001.

This is not an emergency. However, some people who drink water containing arsenic in excess of the MCL over many years could experience skin damage or problems with their circulatory system, and may have an increased risk of getting cancer.

You do not need to use an alternative water supply. However, if you have health concerns, you may want to talk to your doctor to get more information about how this may affect you. We are taking the following actions to address this issue: The City of Seagraves will provide filtered/treated water with reduced arsenic and fluoride levels to the public directly from the water system to the tap. The City is waiting for TCEQ to give final approval of the CeramicUltraFiltration system.

Please share this information with all people who drink this water, especially those who we may not have reached or received this notice directly (i.e., people in apartments, nursing homes, schools, and businesses). The public works office has extra copies for anyone interested.

If you have questions regarding this matter, you may contact: Renee Goodger at 806-387-2013

Violation Sample Results Report:
CITY OF SEAGRAVES PWS ID: TX0830001

EP001

Violation ID Number	Monitoring Period	Violation Description	Analyte Description	Calculated Compliance Value
100068344	4Q2021	MCL AVERAGE	ARSENIC	0.035 mg/L

Results for Quarter 3 of 2021: ARSENIC

Sample ID: Q2128858003 07/07/2021 TRT-TAP 0.1 MG GST AT CITY YARD 0.0311 mg/L

Results for Quarter 2 of 2021: ARSENIC

Sample ID: Q2111778002 07/07/2021 TRT-TAP 0.1 MG GST AT CITY YARD 0.0359 mg/L

Results for Quarter 2 of 2021: ARSENIC

Sample ID: Q2109005001 04/08/2021 TRT-TAP 0.1MG GST AT CITY YARD 0.0329 mg/L

Results for Quarter 1 of 2020: ARSENIC

Sample ID: Q2101036003 01/14/2021 TRT-TAP 0.1 MG GST AT CITY YARD 0.0381mg/L

